

WELL COMPLETION REPORT
3/71

PUTNAM COUNTY DEPARTMENT OF HEALTH
Division of Environmental Health Services
COUNTY OFFICE BUILDING - CARMEL, NEW YORK

This report is to be completed by well driller and submitted to County Health Department together with laboratory report of analysis of water sample indicating water is of satisfactory bacterial quality before certificate of construction compliance is issued.

REPORT MUST BE SUBMITTED WITHIN 30 DAYS OF WELL COMPLETION

P1101

41 28 35


73 32 08

OWNER	NAME LA BANCA, Frank		ADDRESS RR #2, Box 382, New Fairfield, CT 06810	
LOCATION OF WELL	(No. & Street) Corner of Andover & Hopewell, Putnam Lake, Patterson, New York		(Town) (Lot Number)	
PROPOSED USE OF WELL	<input checked="" type="checkbox"/> DOMESTIC <input type="checkbox"/> BUSINESS ESTABLISHMENT <input type="checkbox"/> FARM <input type="checkbox"/> TEST WELL <input type="checkbox"/> PUBLIC SUPPLY <input type="checkbox"/> INDUSTRIAL <input type="checkbox"/> AIR CONDITIONING <input type="checkbox"/> OTHER (Specify)			
DRILLING EQUIPMENT	<input type="checkbox"/> ROTARY <input checked="" type="checkbox"/> COMPRESSED AIR PERCUSSION <input type="checkbox"/> CABLE PERCUSSION <input type="checkbox"/> OTHER (Specify)			
CASING DETAILS	LENGTH (feet) 41	DIAMETER (inches) 6	WEIGHT PER FOOT 19	<input checked="" type="checkbox"/> THREADED <input type="checkbox"/> WELDED <input checked="" type="checkbox"/> DRIVE SHOE <input type="checkbox"/> NO <input checked="" type="checkbox"/> WAS CASING GROUTED? <input type="checkbox"/> NO
YIELD TEST	<input type="checkbox"/> BAILED <input type="checkbox"/> PUMPED <input checked="" type="checkbox"/> COMPRESSED AIR		HOURS 4	G.P.M. 12
WATER LEVEL	MEASURE FROM LAND SURFACE - STATIC (Specify feet) 20		DURING YIELD TEST (feet) 160	
SCREEN DETAILS	MAKE			LENGTH OPEN TO AQUIFER (feet)
	SLOT SIZE	DIAMETER (inches)	IF GRAVEL PACKED:	GRAVEL SIZE (inches) FROM (feet) TO (feet)

530 S

DEPTH FROM LAND SURFACE FEET to FEET		FORMATION DESCRIPTION
0	12	Silt, Sand, Gravel
12	30	Loose Sand And Gravel
30	160	Medium-Hard Granite

Sketch exact location of well with distances, to at least two permanent landmarks.



If yield was tested at different depths during drilling, list below

FEET	GALLONS PER MINUTE
100	3 1/2
160	12

DATE WELL COMPLETED 3/23/82 DATE OF REPORT 3/24/82 WELL DRILLER (Signature) Robert M. Hill

Robert M. Hill, President-HILL DRILLING CO., INC.